

# TREX-DM

The use of gas time projection chambers (TPCs) with Micromegas readouts has been recently proposed to search for low mass WIMPs, as part of the T-REX project. Many of the technical advantages exploited in the development of the detectors for axion research are of direct application also in this case. Namely, the possibility to build Micromegas readouts with radiopure materials and with a signal extraction scheme of extreme radiopurity

or the capability to use topological discrimination techniques based on the highly granular readout. In addition, the way event detection happens in gas (i.e. drift of charge and signal amplification confined in the Micromegas structure) allows, in principle, to reach very low energy threshold even in relatively large size detectors. Another aspect, very important for application to WIMP searches, are the scaling-up prospects. Technical solutions for scaling-up via tessellation of identical microbulk detectors have been defined.




The TREX-DM TPC has been designed to host 0.3 kg of argon mass at 10 bar (or, alternatively, 0.16 kg of neon). It is composed of a cylindrical vessel made of radiopure copper, with an inner diameter of 0.5 m, a length of 0.5 m and a wall thickness of 6 cm. These dimensions are set by the requirements that the vessel holds up to 10 bar of pressure, while at the same time constitutes the innermost part of the shielding. The vessel is divided into two active volumes by a central mylar cathode, which is connected to high voltage by a tailor-made feedthrough. At each side there is a 19 cm long field cage defined by a series of copper strips imprinted on a kapton substrate supported by four teflon walls.

Recientemente se ha propuesto el uso de las cámaras de proyección temporal (TPC) de gas con lecturas de Micromegas para buscar WIMP de baja masa, como parte del proyecto T-REX. Muchas de las ventajas técnicas explotadas en el desarrollo de los detectores de axiones son de aplicación directa: la posibilidad de construir lecturas de Micromegas con materiales radiopuros y con un esquema de extracción de señal de radiopuridad extrema o la capacidad de utilizar técnicas de discriminación topológica basadas en la lectura altamente granular. Además, la forma en que ocurre la detección de eventos en el gas (es decir, deriva de carga y amplificación de señal confinada en la estructura de Micromegas) permite, en principio, alcanzar un umbral de energía muy bajo incluso en detectores de tamaño relativamente grande. Otro aspecto, muy importante para la aplicación a las búsquedas WIMP, son las perspectivas de ampliación a través de la teselación de detectores idénticos.

La TPC TREX-DM ha sido diseñado para albergar 0,3 kg de masa de argón a 10 bar (o, alternativamente, 0,16 kg de neon). Se compone de un recipiente cilíndrico de cobre radiopuro, con un diámetro interno de 0,5 m, una longitud de 0,5 m y un espesor de pared de 6 cm, dimensiones establecidas por los requisitos de que el recipiente soporte hasta 10 bares de presión, mientras que al mismo tiempo constituya la parte más interna del blindaje. El recipiente está dividido en dos volúmenes activos por un cátodo central de mylar, que está conectado a alta tensión. A cada lado, hay una jaula de campo uniforme de 19 cm de largo definida por una serie de tiras de cobre impresas en un sustrato de kapton sostenido por cuatro paredes de teflón.





TREX-DM detector installation at LSC has been completed in 2018 and the experiment has moved into the commissioning phase. The gas system is fully installed, the shielding mounted (except for the neutron shielding), and the slow control system, readout electronics, and one detector plane are already operative. First commissioning (calibration and background) data have been already taken at low pressure Ar, and their preliminary assessment is positive. The main points developed are: a) The detector is fully equipped and installed inside its lead castle. The gas system installation has been completed and certified by an authorized body to operate at high pressure. A first complete version of the slow control, sufficient to efficiently and safely operate the detector is already in place and has been operative in continuous way for several weeks now. b) The inner part of the shielding, including the lead castle with the inner copper lining, the top structure, and the plastic enclosure to allow evaporated N<sub>2</sub> (or Rn-free air) flushing, are completed. c) Both calibration (with a <sup>109</sup>Cd source) and few-days-long background runs have already been taken with Ar + 1% Isobutane at 1.5 bar. d) The background model of the TREX-DM setup is complete.

La instalación del detector TREX-DM en LSC se completó en 2018 y el experimento está en la fase de pruebas. El sistema de gas está completamente instalado, el blindaje montado (excepto el blindaje de neutrones) y el sistema de control, la electrónica de lectura y uno de los planos del detector ya están operativos. Los primeros datos de la puesta a punto (calibración y antecedentes) ya se han tomado con argón a baja presión, y su evaluación preliminar es positiva. Los principales puntos desarrollados son: a) El detector está totalmente equipado e instalado dentro de su castillo principal. Se ha completado la instalación del sistema de gas y certificado para operar a alta presión. Ya existe una primera versión completa del sistema de control, suficiente para operar el detector de manera eficiente y segura, operativa de manera continua durante varias semanas. b) se ha completado la parte interna del blindaje, incluido el castillo de plomo con el revestimiento interno de cobre, la estructura superior y el recinto de plástico para permitir el evaporado de N<sub>2</sub> (o aire libre de Rn). c) Tanto la calibración (con una fuente de <sup>109</sup>Cd) como los fondos ya se han tomado en argón con isobutano al 1% a 1,5 bar. d) Se ha completado el modelo de fondo de la configuración TREX-DM.